

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245413  
Address: 3211 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Wednesday, May 14, 2025

Corrective Action Required:

1	Misc	3211 SW Arboridge circle - as graded plot plan needed - Final driveway inspection needed - Seal top of AC disconnect - Install sod, splash blocks and sump discharge 36" from house - Bottom garage door brackets required to be within 18" of floor - Install 2, 1/2" thru bolts or approved bracket on the two outer posts of upper stair landing -
---	------	--

Comments: