

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, May 15, 2025

Corrective Action Required:

1	Misc	-Complete sod, splash blocks etc. -Obtain lawn irrigation permit and backflow certificate -Wet rated receptacles required at all exterior receptacles -Garage door must self close and latch -Install (2) 1/2" through bolts at deck post to beam connections -Install light fixture at kitchen
---	------	--

Comments: