

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245421
Address: 2226 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Thursday, May 15, 2025

Corrective Action Required:

1	Misc	226 SW Crown dr <ul style="list-style-type: none">- missing security screws in front door jambs- Garage outlets not correctly wired , reversed polarity- Reinstall lights in master bathroom- Thru-bolts or approved brackets missing on post to beam connection of deck- Missing smoke / carbon monoxide detector in basement mechanical room- Seal around AC disconnect and service box- Drive ground rod completely into ground- Obtain final driveway inspection
---	------	---

Comments: