



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O. BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113727, Building Permit - Commercial  
Address: 2741 NE MCBAIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Monday, January 23, 2012

### Corrective Action Required

1 MISC

### OK TO COVER BELOW:

-MECHANICAL UNITS SCREEN WALLS

-1ST FLOOR IN-WALL

-1 HR WALL IN ELEVATOR EQUIPMENT RM- OK TO ROCK

### Comments: