

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243632  
Address: 1538 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Thursday, May 15, 2025

Corrective Action Required:

1	Misc	As graded plot plan submitted, but needs 6' of fall on 3 sides of house and storm inlet cleaned. Can see that lot slopes back to house simply by looking at fence. TCO extended for 30 days
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**