

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245813  
Address: 1937 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Jamie Simerly	Failed	Friday, May 16, 2025

Informational:  
1      Misc      05-09-25 Jamie S, DW is formed compacted. Approved to pour.  
05-16-25 Jamie S, DW is missing grout at the curb as discussed with contractor. Call in for reinspection once grout is applied.

**Comments:**