

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250366  
Address: 2713 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, May 16, 2025

Corrective Action Required:

1	Misc	2713 sw 12 street
		- Struts over bathroom and master closet landing on non load bearing wall
		- fire block top plate at gable wall in great room above fireplace
		- Fire block top plate fur out in bedroom 5 window

**Comments:**