

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250248
Address: 2758 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|-------------|----------|----------------------|
| Sidewalk Inspection | Devon Perry | Partial | Friday, May 16, 2025 |

Informational:
1 Misc 5-8-25 DP. SW is formed, cross slopes in compliance, aggregate compacted.
Approved to pour.

5-16-25 DP. Will pass sidewalk once erosion control is reestablished.

Comments: