

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251324  
Address: 1201 NE LEGACY PARK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                            | Inspector:   | Outcome: | Date:                |
|--|--------------|----------|----------------------|
| <b>Footing Inspection - Commercial</b> | Khanh Nguyen | Failed   | Friday, May 16, 2025 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | Permit address should be 1300 NE Legacy Park Dr, not 1201 NE Legacy Park Dr |
|   |      | Provide (6)#5 rebar EW top&bottom   |

**Comments:**