

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240340

Address: 1923 NE DISCOVERY AVE, LEES SUMMIT, MO 64064
1921 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Friday, May 16, 2025

Informational:

1 Misc

Exterior footing OK:

-7.7/F.9 to 10.4/F.9 to 13/D.9; 12.5/D.2 to 7.5/D.2;

-Cont. from 7.7/F.9 to 6.5/F.9; area 5.5/F.9 to 6.5/F.1 (rm 1003-1006), except at fire riser blockout; cont. to 6/D.9

-SE stair tower pad and f. wall

Corrective Action Required:

2 Misc

P2 pedestal rebars not per plan. See detail 2/S503

Comments: