

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243494  
Address: 2774 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Monday, May 19, 2025

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | - REVISE as graded plot plan TO SHOW EXPANDED PATIO   |
|   |      | -( Uncover amd Raise)<br>water meter pit to grade with meter 14-18" below lid, dig out dirt and<br>have at least 2" of gravel in bottom |
|   |      | - land sewer trace wire at grade  |
|   |      | - Seal top of AC disconnect   |
|   |      | - Provide tamper resistant caps at compressor   |

Comments: