

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243851
Address: 2139 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, May 19, 2025

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of sod -provide cap for basement bath vanity plumbing -install water anti siphon device at basement water spigot
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: