# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRCOM20240118

Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: **Rated Assembly Inspection** Robb Popp Partial Tuesday, May 20, 2025 Corrective Action Required: Misc -Complete fur downs around plumbing etc, seal penetrations at corridors \*\*HVAC chases at atrium: -Complete shaft assembly at ceiling lines, install shaft liner over DWV void Corrective Action Required: **ELEVATOR 1** -Shaft layer approved -1st and 2nd layer approved Corrective Action Required: **ELEVATOR 2** -Ceiling assembly complete 3 Corrective Action Required: STAIR TOWER 1 Corrective Action Required: STAIR TOWER 2 RC at ceilings ok DRYWALL 1ST FLOOR SCREW PATTERN

Corrective Action Required:

6 STAIR TOWER 3 Corrective Action Required:

FIRST FLOOR -RC at ceiling joists and 16" below ceiling at corridor walls from 135-108

-Screw pattern at corridor ceiling ok

-RC complete

-Screw pattern at atrium ceiling

### Informational:

8 SECOND FLOOR -RC at ceiling joists and 16" below ceiling at corridor walls from 235-208

-Screw pattern at corridor ceiling ok -Screw pattern at corridor ceiling ok

217-1st and 2nd layer at non shaft assembly walls both sides, both shafts

217- RC approved -RC approved

-Screw pattern at units and corridor to firewall except as noted:

-Screw pattern at atrium ceiling

Informational:

9 THIRD FLOOR

complete

Informational:

10 FOURTH FLOOR complete

## **Comments:**