

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRPR20252038  
Address: 2532 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - R</b>	Drew Fischer	Failed	Tuesday, May 20, 2025

Corrective Action Required:

1	DCM8 Water Meter Height	THE TOP OF THE WATER METER TO BE SET AT A DEPTH OF 14 TO 18 INCHES BELOW THE WATER METER LID. Meter set at 24", waiting on water department approval
---	-------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**