

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Wednesday, May 21, 2025

Corrective Action Required:	
1        Misc	-Complete fur downs around plumbing etc, seal penetrations at corridors

    \*\*HVAC chases at atrium:  
    -Shaft layer complete

Corrective Action Required:	
2        ELEVATOR 1	-Shaft layer approved -1st and 2nd layer approved

Corrective Action Required:	
3        ELEVATOR 2	-Ceiling assembly complete

Corrective Action Required:	
4        STAIR TOWER 1	

Corrective Action Required:	
5        STAIR TOWER 2	RC at ceilings ok

    DRYWALL 1ST FLOOR SCREW PATTERN

Corrective Action Required:	
6        STAIR TOWER 3	

Corrective Action Required:	
7        FIRST FLOOR	-RC at ceiling joists and 16" below ceiling at corridor walls from 135-108 -Screw pattern at corridor ceiling ok -RC complete

Informational:		-Screw pattern at atrium ceiling
8	SECOND FLOOR	-RC at ceiling joists and 16" below ceiling at corridor walls from 235-208 -Screw pattern at corridor ceiling ok -Screw pattern at corridor ceiling ok 217- 1st and 2nd layer at non shaft assembly walls both sides, both shafts 217- RC approved -RC approved -Screw pattern at units and corridor to firewall except as noted: -Screw pattern at atrium ceiling
Informational:		
9	THIRD FLOOR	complete
Informational:		
10	FOURTH FLOOR	complete

**Comments:**