

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250352
Address: 1937 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Wednesday, May 21, 2025

Corrective Action Required:

1	Misc	-Panel splice to be in the middle 24" of the portal leg -nailing incomplete at time of inspection -straps not secured all inspection not performed -no portal frame inspections till all rough inspectionWes Bears 05/02/2025 11:25 AM
---	------	---

Corrective Action Required:

2	Misc	No City Stamped blue prints on site
---	------	-------------------------------------

Comments: