

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20230994  
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Wednesday, May 21, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-Complete corrections for all other departments</li><li>-Secure grounding conductor at all light poles</li><li>-Paint all exterior metallic gas lines</li><li>-Close gap at receptacle across from restrooms</li><li>-Install cover plates at unused boxes</li><li>-Label all panels</li><li>-Provide panel schedules at all panels</li><li>-Breakers not allowed to be over 67" off to center of breaker</li><li>-Install lockouts at all sign breakers</li><li>-Provide ASSE 1022 backflow device at carbonated beverage machine</li><li>-Secure rooftop ladder</li><li>-Clean all trash from roof</li><li>-Label all RTUs and breakers</li><li>-Secure all electrical within 12" of disconnects on rooftop</li><li>-Floor elevations not to be over 1/4" at sales entry ramp</li></ul>
---	------	---

Comments: