

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242360  
Address: 1812 NE LASHBROOK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Tuesday, May 20, 2025

Corrective Action Required:

1	Misc	-Attach deck beam to each post with two 1/2" through bolts/washers/nuts or equivalent connections **I don't see the two through carriage bolts, especially at the south post. Verification is required. See IRC figures R507.5.1(1 and 2)
---	------	---

Comments: