

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241047

Address: 1450 SW WINTHROP TER, LEES SUMMIT, MO 64081
1448 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, May 22, 2025

Corrective Action Required:

1 Misc

- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- address pending driveway inspection

1448

- missing secondary locking device at rear slider

Comments: