

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243851
Address: 2139 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Thursday, May 22, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Ready for Temp CO	Wednesday, May 21, 2025
Corrective Action Required:			
1 Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of sod		

Comments: