

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245916

Address: 1408 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1406 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mitchell Schwarz	Failed	Thursday, May 22, 2025

Corrective Action Required:

1	Misc	Rated Roof decking does not extend 4' in some areas in 1406 -Joist spaces in basement okay -separation wall in attic okay
---	------	---

**Comments:**