

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20250471  
Address: 2610 SW FIREFLY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Drew Fischer	Failed	Friday, May 23, 2025

Informational:

1	Misc	Portal frame only front and back porch
---	------	--

Corrective Action Required:

2	Misc	2610 SW Firefly <ul style="list-style-type: none"><li>- Check bolts are middle 1/3rd of bottom plate in garage</li><li>- Security blocking at back door</li><li>- Fire blocking at top of 2 cavities on right and of fireplace</li><li>- Fire blocking around post beam connection in stairway landing</li><li>- Fire blocking at wall to soffit at bottom of stairs</li><li>- Check top of steel post to beam connections in basement for fire blocking</li><li>- Check fire blocking at all exterior walls in basement</li><li>- Secure wire in soffit in bedroom 4 downstairs</li><li>- Strap top plate at vent pipe in master bathroom</li><li>- Address electrical in return air basement</li><li>- Provide 1 1/2" bearing on bottom of stairs Check top stringers</li><li>- Address cable/cat wire in return air in basement</li></ul>
---	------	--

Comments: