

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250605
Address: 1034 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, May 23, 2025

Corrective Action Required:

3	Misc	- missing truss hangers above double garage door - Fur out(protect gas piping) from vehicle damage - Fire block penetrations in floor at refrigerator - Fire block top of HVAC chase on garage side of kitchen wall - Fire block landing of stairs 1 to second floor
---	------	---

Comments: