

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245553  
Address: 3211 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Ready for Temp CO	Friday, May 23, 2025

Corrective Action Required:

1	Misc	3211 SW Arbor Sound <ul style="list-style-type: none"><li>- yard grading needs to be completed and sod installed</li><li>- splash blocks need to be in place and sump discharge installed</li><li>-pay all outstanding fees</li><li>-driveway and sidewalk final inspections</li><li>- completed plot plan inspection needed</li></ul>
---	------	--

**Comments:**