

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245916

Address: 1408 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1406 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, May 27, 2025

### Corrective Action Required:

1	Misc	1406 -fireblock furr down ends in basement bed 4 and gaps in bed 4 closet
		1408 Okay

### Comments: