

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242861

Address: 1444 SW WINTHROP TER, LEES SUMMIT, MO 64081
1442 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, May 27, 2025

Corrective Action Required:

1	Misc	-Address pending driveway inspection. -land sewer tracer wire in locator box
		1442 okay
		1444 -plug splitter not allowed at sump pump single pull receptacle

Comments: