

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246494
Address: 2734 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Wednesday, May 28, 2025

Informational:

1	Misc	Garage PFH okay. Only. Rear cspf exterior nailing ok
---	------	---

Corrective Action Required:

2	Misc	2734 SW Heartland rd - Front door sill height needs to be no more than 7 3/4" - Fire block around drain vent pipe in garage - Check all plumbing drain and vent pipe pass thru top plate for fire block - Strap drain pipe in master bathroom - Double check other fire blocking
---	------	---

Comments: