

## **PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

Permit #:PRPWRW20252108, Public Works Right of Way Permit Address: 1522 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Site Visit Inspection** Matt Munger Partial Wednesday, May 28, 2025

Corrective Action Required

1 Misc Site visit - the approach met requirements for depth and

compaction. The existing sidewalk panels that meet the approach will need to be torn out due to being damaged. They will pour the approach and come back to replace the damaged sidewalk panels. I spoke with Colby about the panels. I marked

the panels with pink paint.

**Comments:**