

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245089
Address: 2786 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, May 29, 2025

Corrective Action Required:

1	Miscellaneous Correction	-R317, Smart siding behind concrete at front stoop at afrage wall, to be 2" gap
		- Provide security screws at front door
		- Fire stop gaps above garage doors at ceiling

Comments: