

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251603
Address: 2090 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Thursday, May 29, 2025

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -STREET CLEAN UP REQUIRED IMMEDIATELY. -POST ADDRESS -MAINTAIN GRAVEL DRIVE WITH MIN 3/4" GRAVEL IN MIN 6" LIFT -MAINTAIN STORM INLET ***Plumbing contractor stated streets would be cleaned before leaving the site after water service inspection. This was not done
---	---	--

Comments: