CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250716

Address: 2708 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Friday, May 30, 2025

Residential

Corrective Action Required:

1 Misc - Address short LVL and sistered 2x 10 joists in kitchen with header (Engineer

leter fastening detail not followed)

- fee added for 5 all rough inspection

Comments: