

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250605  
Address: 1034 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, May 30, 2025

**Corrective Action Required:**

1	Misc	- missing truss hangers above double garage door ( LUS24 on B2 ) - Fire block top of HVAC chase on garage side of kitchen wall - Fire block landing of stairs 1 to second floor
---	------	---

**Comments:**