

CITY OF LEE'S SUMMIT

Development Services Department

220 SE Green Street

Lee's Summit, MO 64063

(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245223

Address: 2120 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

Pool Steel/Bonding - Residential

Mitchell Schwarz

Partial

Friday, May 30, 2025

Informational:

1

Misc

- (4) points at shell and skimmer basket bond to perimeter approved

-perimeter and hand rail bonded

Comments: