

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244652  
Address: 1101 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:  | Outcome: | Date:                |
|----------------------------|-------------|----------|----------------------|
| <b>Sidewalk Inspection</b> | Devon Perry | Failed   | Friday, May 30, 2025 |

Informational:  
1 Misc

05-28-25 Jamie S, SW does not have the required 3 inches of aggregate in spots and has standing water on the north side.

5-30-25 DP. SW does not have required aggregate depth, talked to contractor and he is going to fix.

**Comments:**