

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection</b>	Dustin Agcopra	Partial	Thursday, May 29, 2025

Informational:  
1      Misc      5-29-24 Dustin A, Sewer service for clubhouse has been connected to the stub.  
5-30-25 Dustin A, Sewer service for building 4 has failed due to section of pipe from cleanout to stub falling backwards.

**Comments:**