

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250605
Address: 1034 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, June 02, 2025

Corrective Action Required:

1	Misc	- Install hold down at stairs corner - missing truss hangers above double garage door (LUS24 on B2) - Fire block top of HVAC chase on garage side of kitchen wall - Fire block landing of stairs 1 to second floor
---	------	---

Comments: