



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20235681	Date:	June 02, 2025
Project Title:	WILSHIRE HILLS III	Applicant:	
Location:			
3200 NE WILSHIRE DR, LEES SUMMIT, MO 64064		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	R-2	KANSAS CITY, MO 64116	
Description:	NEW AGE RESTRICTED		
APARTMENT BUILDING		Primary: (913) 888-0647	

PARTIAL PERMIT ISSUANCE FOR SITE DEVELOPMENT,
FOOTINGS, UNDERSLAB AND SLAB ONLYMike
Weisenborn 08/30/2024 7:57 AM
Construction Type: Type VA (1 hour)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Action Required: Change fire department connection to a 4" storz with a 30 degree elbow.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.