

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245538
Address: 2770 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Tuesday, June 03, 2025

Corrective Action Required:

1	Misc	- Sidewalk and driveway inspection pending - Provide splash pads - Pay all fees - Final grading and sod - Sump discharge to be 36" away from foundation - land sewer trace wire at grade
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	Extention approved 6/3/2025
---	------	-----------------------------

Comments: