## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20226232

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Shawn Hoffman Partial Friday, May 23, 2025

Corrective Action Required:

1 FIRST FLOOR Addition side complete except at Clean room 1E-169 (Transition to existing

for next phase)
\*Existing side:

-1E-222 shaft layer-Seal penetrations

Building Support 02-1E222 & Soiled Hold 02-1E223-Seal all penetrations

Lid on level 1 in corridor 1E-200g by 1E-311

Corrective Action Required:

2 SECOND FLOOR Addition side complete

-2E-237

Corrective Action Required:

3 THIRD FLOOR -Shaft and 1st and 2nd layer at 3E-303

-Screw pattern at 3E-322, 323, 365, 264, 263 -Shaft,1st & 2nd layer at South Elevator

-Shaft, 1st and 2nd layer layer at North elevator

Comments: