

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250722
Address: 2108 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Tuesday, June 03, 2025

Corrective Action Required:

1	Misc	-PFH at garage open is good -Front and back porch ceilings are ok to -cover - cs-pf on dining room back wall and owners suite back wall need appropriate sized straps on inside and as per code 3" grid pattern nailing at headers
---	------	--

Comments: