



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20252272	Date:	June 04, 2025
Project Title:		Applicant:	
Location:			
610 NW BLUE PKWY, LEES SUMMIT, MO 64063		GOAL FIRE PROTECTION, LLC	
Type of Work:		20920 147TH ST	
Occupancy Group:		BASEHOR, KS 66007	
Description:	EXTENSION OF EXISTING FIRE	Primary: (913) 441-3390	
SPRINKLER SYSTEM TO PROTECT UNDER GRATED			
MEZZANINE.			
Construction Type:			
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Safety margin must be 5 or greater.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.