

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20246376  
Address: 41 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Robb Popp	Failed	Wednesday, June 04, 2025

Informational:  
1 Misc

05/07/25 Wednesday JMJ  
Erosion control appears to be functioning properly.

05/27/25 Tuesday JMJ

06/04/25 Wednesday JMJ  
Erosion control appears to be functioning properly.  
Erosion control has failed along NW Commerce Drive mud at the entrance  
clogged gutter buddies along NW Commerce Drive.

**Comments:**