

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245956  
Address: 1916 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Wes Bears	Failed	Thursday, June 05, 2025

**Corrective Action Required:**

1	Misc	-no receptacle covers in kitchen at countertop -secondary lock on patio door -open light fixture at back patio -irrigation permit required
---	------	---

**Comments:**