

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250475
Address: 1917 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-------------------------|
| All Rough Inspection - Residential | Wes Bears | Failed | Thursday, June 05, 2025 |

Corrective Action Required:

| | | |
|---|------|--|
| 3 | Misc | -fire block fur out in upstairs bathroom shower -truss hanger missing upstairs in the bedroom "truss 7" -plans contradict on support pole size |
|---|------|--|

Comments: