

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20252158  
Address: 2779 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, June 06, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- complete fire blocking on exterior fur down walls at top plate</li><li>- Draft stop vertical every 10' or less in exterior walls</li><li>- Fire block penetrations in return air</li><li>- Draft stop gaps at top plate throughout</li><li>- Provide security blocking at exterior door</li></ul>
---	------	---

**Comments:**