



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20252108, Public Works Right of Way Permit
Address: 1522 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Eric Wiggins	Partial	Friday, June 06, 2025

Corrective Action Required

1	Misc	Site Visit- the approach does not meet ADA standards. It will need to be torn out as well as the damaged sidewalk panels.
---	------	---

Corrective Action Required

2	Misc	Site visit. pre-pour driveway approach meets all specifications, including ADA. Will check back after it is poured.
---	------	---

Comments: