

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250096
Address: 2821 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Friday, June 06, 2025

Corrective Action Required:

1	Misc	Portal frame inspection only Pfh-ok , bed/office missing cspf
---	------	---

Corrective Action Required:

2	Misc	2821 SW Heartland rd - Security screws needed in front door hinges - Move or use appropriate fire protection, 3 electrical boxes in wall garage entry/kitchen return air vents - Support straps on plumbing vents in master bathroom - Security screws in basement walkout door
---	------	---

Comments: