## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## OnlinePortal at DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

Permit #: PRCOM20235681

Address: 3200 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Monday, June 09, 2025

Commercial

Corrective Action Required:

1 Misc Interior shearwall:

-1st floor

Corrections:

-Exterior wall sheathing nail-Nail 8d @ 6" oc

Corrective Action Required:

2 FIRST FLOOR -Corridor ceiling pre-rock OK

Corrective Action Required:

3 SECOND FLOOR -Corridor ceiling pre-rock OK

**Comments:**