

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251365  
Address: 1047 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, June 09, 2025

Corrective Action Required:

1	Misc	PORAL FRAME AND FRONT PORCH ONLY
---	------	----------------------------------

- Could not inspect nail patern down each leg of portal frame this is covered by trim.
- Could not inspect porch framing this has been covered.

**Comments:**