

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250632
Address: 2225 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Monday, June 09, 2025

Corrective Action Required:

1	Misc	Portal frame at garage door missing interior straps
---	------	---

Corrective Action Required:

2	Misc	2225 SW Crown <ul style="list-style-type: none">- Bolts in middle 1/3rd of plate in garage- Protect wire within 6' of attic access- Nails in joist hanger in master bedroom- Fire blocking in space above bedroom 2 closet- Bolt post to floor in basement- Attach stud at bottom of stairs-
---	------	--

Comments: